



BUREAU VERITAS GAZELLE (PTY) LTD

**CERTIFICATE OF ANALYSIS**

Vessel	MT HIGH FIDELITY
Client	TRAFIGURA/VITOL
File Reference	CT7497.19
Date of Certificate	08 July 2019
Sample Date and Time	08 July 2019, 19h00
Discharge Port	Cape Town Harbour, South Africa

Sample Source	<b>Shore Tank 6 After Discharge</b>	Product Name	<b>Gasoil 10ppm</b>
Date and Time Tested	08 July 2019, 20h00	Terminal/Berth	Burgan/ Eastern Mole 2
Condition of Sample	Good	Sampling Method	ASTM D4057
Sample Drawn By	Bureau Veritas Gazelle		

Test	Units	Method	Specification	Results
Appearance	-	Visual	Bright & Clear	Bright & Clear
Density @ 20°C	Kg/L	ASTM D4052	0.800 min	0.8414
Electrical Conductivity	pS/m	ASTM D2624	200 min	234

David Vlotman  
Bureau Veritas Gazelle

\* Denotes tested by third party laboratory

\*\*Denotes product does not meet specification

This certificate relates specifically to the sample/s tested as received. This test report shall not be reproduced except in full, without written approval of the laboratory. Analysis has been performed in accordance with the latest issues of the relevant test methods. Standard Terms and Conditions of Business of Bureau Veritas will apply